



Nobody does it better than Pool Tech.

319-365-8609 | fax 319-365-8568 | 1-800-677-7665

3233 First Av SE | Cedar Rapids, Iowa 52402

www.pooltech.com

10/16/2013

Matt Ciders
City of Mt. Vernon
213 First Street NW
Mt. Vernon, IA 52314

The following is the results of our site visit to the Mount Vernon City Pool on Monday September 30, 2013.

Repair the interior of the pool just under the role out gutter and the expansion joint near the deep end. The amount for this could vary on total linear feet of repair done. Budget \$6,000.00 to \$8,000.00

Adding a heater to the pool would require the city to furnish the gas line to the heater and electricity to the heater. Budget for the heater and piping to return line would be approximately \$25,000 to \$30,000.00

New chemical controller, Chlorinator, and Acid pump \$6,700.00.

New filter system for the pool, which would include demo of old filters installation of new filter repiping to existing pumps, and piping to return lines new sand and engineering. Budget for this phase would be \$65,000.00 to \$80,000.00.

If you have any questions please give me a call 319-361-7910.

Prepared by:

Charlie Rochford
Vice President
Pool Tech Midwest, Inc.
319-361-7910 cell
crochford@pooltech.com